

Compact Circuit Protector (CCP)

Recommended Lock-out devices:

Brady Pin out device P/N 90844

Ideal P/N 44-779

Accessories

Catalog Number	Description	Configuration	Signal Output	Minimum Circuit Voltage	Approvals
CCP-AUX	Auxiliary Contacts NO+NC for Switch Status	1 per CCP	5A/240Vac	–	UL98 Recognized and CSA 22.2 No. 4-04, IEC60947-5 AC15
CCP-PLC-IND	Wired Remote Fuse Indication for PLC Applications	1 per CCP	24Vdc	100Vac	UL98 Recognized and CSA 22.2 No. 4-04
ICM-DIN*	Intelligent Circuit Monitor for Cooper InVision™ System	1 per pole	RF	100Vac	UL508 Listed and CSA Certified

*Refer to data sheet 1068



CCP-AUX



CCP-PLC-IND
(Includes spade terminals)



ICM-DIN